

Certificate of Compliance

Certificate Number **270306 - S8301A**
Report Reference **S8301, August 21st, 2003**
Issue Date **2006 March 27**

Page 1 of 2



Issued to:

Airsense Technology Ltd

**Wilbury Way - 71 Knowl Piece
SG4 0TY Hitchin Hertfordshire United Kingdom**

*This is to certify that
representative samples of*

Aspirating smoke detector

air sampling, laser, Model Airsense Stratos HSSD2.

air sampling, laser, Model Airsense Stratos HSSD Minimum Display option.

*Have been investigated by Underwriters Laboratories Inc.® in
accordance with the Standard(s) indicated on this Certificate.*

Standard(s) for Safety:

UL 268 - Smoke-Automatic Fire Detectors


UL 268A - Smoke Detectors for Duct Application

CAN/ULC-S529 - Smoke Detectors for Fire Alarm Systems

Additional Information:

See Addendum for Electrical Ratings

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: **Dan Michael**
Dan Michael, Project Engineer

UL International (U.K.) Ltd.

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc.

For questions in United Kingdom, you may call +44 0 1483 302130.

Reviewed by: **Vito Bellantuono**
Vito Bellantuono, Engineering Group Leader

UL International (U.K.) Ltd.

Certificate of Compliance

Certificate Number **270306 - S8301A**
Report Reference **S8301, August 21st, 2003**
Issue Date **2006 March 27**

Page 2 of 2



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL, cUL requirements.

Detector	Base	Normal Standby		Alarm	
		Voltage, V dc	Current, mA	Voltage, V dc	Alarm, mA
Stratos HSSD2	N/A	21.6 to 26.4	850	21.6 to 26.4	850
Stratos HSSD2 Minimum Display Variant		21.6 to 26.4	850	21.6 to 26.4	850

Issued by:

Dan Michael, Project Engineer

UL International (U.K.) Ltd.

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. UL International (UK) Ltd.

Reviewed by:

Vito Bellantuono, Engineering Group Leader

UL International (U.K.) Ltd.